



COUNTY OF RANDOLPH
 Department of Building Inspections
 204 E Academy St • Asheboro NC 27204-0771

TEMPORARY POWER / OCCUPANCY REQUEST FORM

Address of Project: _____ Permit #: _____

General Contractor, Electrical Contractor, or Property Owner: _____

Address : _____ Phone Number: _____

City State Zip : _____

System to be energized:	Electrical	Reason Power is needed:	Construction
	Mechanical		Occupancy
	Plumbing		

Duration is 90 days

1. In the event no general contractor is involved, the electrical contractor or owner may fill out form.
 2. It must be indicated on this form what is intended for connection at time of release per NC Administration requirements*.
 3. Temporary electrical service is for construction use only. Temporary lighting/outlets shall be installed according to NEC 590.
 4. The roof and all outside windows and doors shall be installed and must be capable of being locked when no one is on premises working...
 5. Applicant shall notify all trades that power is going to be turned on prior to energizing.
 6. During the time that the applicant is not on the job site the energized system shall be secured and locked.
 7. During work hours the energized electrical system shall be constantly supervised by the applicant, if not secured. If left unsecured and unsupervised, notice may be sent to the local utility to de-energize the system.
 8. All other areas to be energized shall be completed, inspected, and approved before energizing. The AHJ (authority having jurisdiction) is the electrical inspector.
 9. AHJ may disconnect power and cancel temporary power permit if any part of new feeders or branch circuits have been energized without inspection. Energizing for testing is OK but power shall not be left on.
 10. No person shall occupy any area of the building before a Certificate of Occupancy or Temporary Certificate of Occupancy has been issued, even for setting up computers. Consult with AHJ about Partial Finaled areas.
 12. The electrical service equipment must be complete; including all grounding and bonding requirements.
 13. All feeders to sub-panels must be installed. Exception: AHJ may give permission not to install.
 14. All 125 volt, 15 and 20 ampere receptacles, authorized by the AHJ for construction use, shall be protected by suitable Ground Fault Circuit-Interrupter protection (GFI).
 15. All line shields, interior trims, or dead front covers shall be installed on utilized panels.
 16. If the General Contractor removes his company from the job, whoever takes over the job shall fill out a new application.
 17. The Temporary Power or Temporary Occupancy shall expire 90 days from date of energization.
- I have read this form and fully understand and agree to the rules and policies as stated: and I further, agree to follow the NC State Building and Administration Code pertaining to Temporary Power and wiring.
18. A Temporary Certificate of Occupancy may only be granted when all electrical, plumbing and mechanical permits have been finaled/approved.

I have read this form and fully understand and agree to the rules and policies as stated: and I further, agree to follow the NC State Building and Administration Code pertaining to Temporary Power and wiring.

 Signature of Building, Electrical Contractor or Property Owner: _____ Date _____



COUNTY OF RANDOLPH
Department of Building Inspections
204 E Academy St • Asheboro NC 27204-0771

TEMPORARY POWER / OCCUPANCY REQUEST FORM

***10.8 TEMPORARY POWER**

10.8.1 Scope. The provisions of this section apply to the utilization of portions of the wiring system within a building to facilitate construction.

10.8.2 Provisions for Temporary Power. The Code enforcement official shall give permission and issue a permit to energize the electrical service when the provisions of 10.8 and the following requirements have been met:

- 1) The service wiring and equipment, including the meter socket enclosure, shall be installed, the service wiring terminated, and the service equipment covers installed.
- 2) The portions of the electrical system that are to be energized shall be complete and physically protected.
- 3) The grounding electrode system shall be complete.
- 4) The grounding and the grounded conductors shall be terminated in the service equipment.
- 5) At least one receptacle outlet with ground fault circuit interrupter protection for personnel shall be installed with the circuit wiring terminated.
- 6) The applicable requirements of the North Carolina Electrical Code apply.

10.8.3 Uses Prohibited. In no case shall any portion of the permanent wiring be energized until the portions have been inspected and approved by an electrical Code Enforcement Official. Failure to comply with this section may result in disconnection of power or revocation of permit.

10.8.4 Application for Temporary Power. Application for temporary power shall be made by and in the name of the applicant. The application shall explicitly state the portions of the energized electrical system, mechanical system, or plumbing system for which application is made, and its intended use and duration.

10.8.5 Security and Notification. The applicant shall maintain the energized electrical system or that portion of the building containing the energized electrical system in a secured and locked manner or under constant supervision to exclude unauthorized personnel. The applicant shall alert personnel working in the vicinity of the energized electrical system to its presence.